

Number	KIP-17530	Replaces	---
Issue date	30-01-2024	Contract number	6700
Due date	29-01-2034	Scope	(EU) 2016/426 (9 March 2016)
Report number	2011915	Module	B (Type testing)
PIN	0476DO1915		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

VICTRIX ZEUS 25
VICTRIX ZEUS 32

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041 - Brescello (RE) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:
EN 15502-1:2021+AC:2022
EN 15502-2-1:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it

www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Maurizio Lorenzon

Digitally signed by:
LORENZON MAURIZIO
Date: 31/01/2024 08:24:56



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

CERTIFICATE

Number KIP-17530 **Page** 1 of 1
Issue date 30-01-2024 **Scope** (EU) 2016/426 (9 March 2016)
Due date 29-01-2034 **Module** B (Type testing)
Report number 2011915
PIN 0476DO1915

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
IMMERGAS

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX ZEUS 25	20,8 – 3,2	25,6 – 3,2
VICTRIX ZEUS 32	29,0 – 4,3	33,1 – 4,3

Appliance types:

B23, B23P, B33, B53, B53P, C13, C33, C43, C53, C63, C83, C93, C13X, C33X, C43X, C53X, C63X, C83X, C93X

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:


Group	mbar	Group	mbar	Group	mbar
E	20	HY20	20; 25	Ls	13
H	20; 25	E(S)	20	M	20
EY20	20	Lw	20	P	37

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H2) when the appliance is set for the reference gas G20.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
 Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-17531	Replaces	---
Issue date	30-01-2024	Contract number	I 6700
Report number	2011915	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476DO1915	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

VICTRIX ZEUS 25
VICTRIX ZEUS 32

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041 - Brescello (RE) - Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:
EN 15502-1:2021+AC:2022
EN 15502-2-1:2022

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager

Maurizio Lorenzon

Digitally signed by: LORENZON
MAURIZIO
Date: 31/01/2024 08:24:08



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-17531	Page	1 of 2
Issue date	30-01-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011915	Module	B (Type testing)
PIN	0476DO1915		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX ZEUS 25

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	20,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,7	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,2	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,0	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	106,8	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17531	Page	2 of 2
Issue date	30-01-2024	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011915	Module	B (Type testing)
PIN	0476DO1915		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX ZEUS 32

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	28,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,4	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	87,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	97,1	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	96,6	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	107,8	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

*The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.*